

Subhead -21
Miscellaneous
Fan, IPS, Dehumidifier, Geysers, Energy Meter, UPS Etc.

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
----------	----------------------	------	---	--	--	--------------------------------------

21.1 CEILING FAN

Supplying & fixing AC capacitor type ceiling fan (without regulator) of following specifications and sizes complete with minimum 305 mm (1 ft) long and 0.75 -1.0" dia, 2.3 mm thickness MS pipe down rod, tempered cast aluminum blades, 2.5 μ f 400V AC capacitor, canopy, double Z ball bearing, best quality silicon sheet core, best quality copper made super enamel wire, aluminum alloyed casting body / metal body having safety pin with powder coated heat / docu paint as required as per BDS 818 etc. connecting PVC wire complete as required.

Rated voltage : 230 volts

Rated frequency : 50 Hz

Rated speed : 300 rpm \pm 5 %

Service value : Minimum 3.5 m³ / min / watt

Temperature rise : Maximum 55°C

Class of Insulation : Minimum E

Noise level : Maximum 60 dB at a distance of 1 meter.

21.1.1 1442 mm. (56") Sweep

21.1.1.1 Input power : Maximum 65 watt.

21.1.1.2 Input power : Maximum 70 watt.

21.1.2 1220 mm. (48") Sweep

21.1.2.1 Input power : Maximum 65 watt.

21.1.2.2 Input power : Maximum 70 watt.

Each	3,914.00	3,911.00	3,898.00	3,898.00
Each	3,730.00	3,727.00	3,714.00	3,714.00
Each	3,620.00	3,616.00	3,604.00	3,604.00
Each	3,497.00	3,493.00	3,481.00	3,481.00

[Handwritten signatures and initials in blue and black ink are present at the bottom of the page, including a large signature on the left and several smaller ones across the bottom.]

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
21.4.2	Providing & fixing U type fan clamp made of 12 mm. dia MS rod having at least 750 mm clearance around and shall be placed above the MS rod mesh of the roof slab including necessary bolts, nuts etc. as required as per sample approved by the Engineer.	Each	135.00	135.00	134.00	134.00
21.5	HEAVY DUTY INDUSTRIAL EXHAUST FAN Supply and installation of Wall mounted heavy duty industrial exhaust fan: Type 230V-240V / 400V-415V, 50 Hz, complete with stainless steel blade, steel frame, standard wall louver shutter with necessary accessories (specially used for kitchen of hospital, student hostel / hall, prison cell, barrack, large auditorium etc).					
21.5.1	16"	Each	3,436.00	3,435.00	3,431.00	3,431.00
21.5.2	18"	Each	3,681.00	3,680.00	3,676.00	3,676.00
21.5.3	24"	Each	4,479.00	4,477.00	4,474.00	4,474.00
21.6	PEDESTAL FAN					
21.6.1	16" Sweep with remote control	Each	4,970.00	4,970.00	4,970.00	4,970.00
21.6.2	22" Sweep without remote control	Each	7,056.00	7,056.00	7,056.00	7,056.00
21.6.3	24" Sweep without remote control	Each	7,424.00	7,424.00	7,424.00	7,424.00
21.7	FAN REPAIRING Full-re-winding the fan by required size of super enameled copper wire, ampere tube, cotton tape, leatheroid paper including heating, varnishing, testing etc. complete as required (dismantle wires shall be taken by the contractor).					
21.7.1	56" AC ceiling fan	Each	1,288.00	1,287.00	1,283.00	1,283.00
21.7.2	48" AC ceiling fan	Each	1,104.00	1,103.00	1,099.00	1,099.00

Subhead 21

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
21.7.3	Pedestal fan	Each	1,227.00	1,226.00	1,222.00	1,222.00
21.7.4	Exhaust fan	Each	1,043.00	1,042.00	1,038.00	1,038.00
21.8	Spray painting the 56" / 48" AC ceiling fan body with blade, canopy, down rod after scraping out the old paint, with anti-corrosive enamel paint etc. with replacing the defective split pin, jam nut, screw etc. including dismantling and re-fixing the fan to the existing place with proper electrical connection.	Each	270.00	269.00	264.00	264.00
21.9	Brush painting AC ceiling fan body with blade, canopy, down rod after scraping out the old paint, with anti-corrosive enamel paint etc. with replacing the defective split pin, jam nut, screw etc. including dismantling and re-fixing the fan to the existing place with proper electrical connection.	Each	221.00	220.00	215.00	215.00
21.10	LABOUR CHARGE					
21.10.1	Labour charge for re-metalling, smoothing the bearing housing or fixing sleeves in the bearing housing of fan.	Each	141.00	137.00	129.00	129.00
21.10.2	Labour charge for fixing bearing.	pair	102.00	99.00	93.00	93.00
21.11	CAPACITOR FOR FAN					
	Supply & installation of the following size fan capacitor (foreign made or equivalent brand accepted / approved by the Engineer).					
21.11.1	2.5 µF	Each	153.00	152.00	148.00	148.00
21.11.2	2.8 / 3.5 µF	Each	160.00	158.00	155.00	155.00
21.12	IPS					

Handwritten signatures and initials in blue and black ink are present at the bottom of the page, including names like 'D.', 'PRC', 'tes', 'ES', 'Dutta', 'Sudh', and others.

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
----------	----------------------	------	---	--	--	--------------------------------------

Supply and installation of following capacity instant power supply (IPS / EPS) complete with central processing unit for 2 hrs. back up service suitable for input supply 220 volt \pm 27%, single phase 50 Hz for output voltage 220 volt \pm 5%, 50 Hz single phase with necessary wiring for light & fan by supplying & fixing all materials as required & complete in all respect as per sample approved by the Engineer.

21.12.1	350 VA	Each	30,799.00	30,796.00	30,788.00	30,788.00
21.12.2	600 VA	Each	36,321.00	36,318.00	36,310.00	36,310.00
21.12.3	1000 VA	Each	47,364.00	47,362.00	47,353.00	47,353.00
21.12.4	1500 VA	Each	67,610.00	67,608.00	67,599.00	67,599.00
21.12.5	2000 VA	Each	79,881.00	79,878.00	79,870.00	79,870.00
21.12.6	3000 VA	Each	128,963.00	128,960.00	128,952.00	128,952.00

21.13 IPS BATTERY

Supply of the following IPS batteries inconformity with BDS IEC standard accepted / approved by the Engineer.

21.13.1	Volt:12V, Amp:70-80AH	Each	11,902.00	11,900.00	11,891.00	11,891.00
21.13.2	Volt:12V, Amp:100-110AH	Each	12,240.00	12,237.00	12,229.00	12,229.00
21.13.3	Volt:12V, Amp:120-130AH	Each	15,338.00	15,336.00	15,327.00	15,327.00
21.13.4	Volt:12V, Amp:150-165AH	Each	18,651.00	18,649.00	18,640.00	18,640.00
21.13.5	Volt:12V, Amp:180-200AH	Each	21,719.00	21,716.00	21,708.00	21,708.00

21.14 AUTOMATIC VOLTAGE STABILIZER

Supply & fixing of Automatic Voltage Stabilizer of following capacities suitable for Input Voltage 140 to 260 Volt, single phase, 50 Hz. for output-220 Volt + 5%, 50 Hz. response within 0.02 sec. with digital control circuit complete as required as per sample accepted / approved by the Engineer.

21.14.1	500 VA	Each	5,276.00	5,274.00	5,265.00	5,265.00
21.14.2	1000 VA - 1200 VA	Each	5,457.00	5,454.00	5,446.00	5,446.00

Handwritten signatures and initials are present below the table, including a large signature in blue ink and several smaller ones in black and blue ink.

Subhead 21

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
21.14.3	2000 VA	Each	6,871.00	6,869.00	6,860.00	6,860.00
21.14.4	3000 VA	Each	11,166.00	11,164.00	11,155.00	11,155.00

21.15 DEHUMIDIFIER

Supply & installation of automatic dehumidifier of following water / moisture extraction capacity workable with relative humidity range 30 - 100% complete with hermetically sealed compressor, thermal & overload protector, blower fan, copper made evaporation & condenser coil with aluminum fins protection, stainless steel moisture container, automatic humidistat to turn the unit "ON" or "OFF" at preselected moisture level, adjustable moisture controller & all other standard accessories suitable for operation at 220 / 240 V, 50 Hz, single phase, AC supply complete as per sample accepted / approved by the Engineer. Major components shall be or made in USA / JAPAN / AUSTRALIA / EU Countries or equivalent accepted / approved by the Engineer.

21.15.1	16 - 20 litres / 24 hr. (suitable for 2000 cft area) Outer body made of stainless steel	Each	22,210.00	22,207.00	22,199.00	22,199.00
21.15.2	25 - 35 litres / 24 hr. (suitable for 3000 cft area) Outer body made of stainless steel	Each	24,664.00	24,661.00	24,653.00	24,653.00
21.15.3	40- 50 liters / 24 hr. (suitable for 4000 cft area) Outer body made of stainless steel	Each	34,480.00	34,478.00	34,469.00	34,469.00
21..15.4	70 -80 liters / 24 hr. (suitable for 5000 cft area) Outer body made of stainless steel	Each	55,340.00	55,337.00	55,329.00	55,329.00

21.16 WATER HEATER / GEYSER

[Handwritten signatures and initials in blue ink are present below the section header, including names like 'Ruhit', 'Sul', and 'AA'. There are also some scribbles and marks.]

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
----------	----------------------	------	---	--	--	--------------------------------------

Providing & installation of following capacity electrically operated water heater containing blue diamond inner tank made of minimum 14 SWG, magnesium anode rod, non-magnetic rust proof galvanized steel & outer jacket, body made of minimum 22 SWG mild steel sheet & 20 mm polyurethane thermal insulation with automatic thermostatic switch with suitable wattage range of

stainless steel Incoloy 800 glass line immersion heating element, thermal cut-out, on-off indicating lamp, Earth Leakage Circuit Breaker (ELCB), safety valve 0.8 MPa, inlet and outlet water connection pipe including fixing accessories all complete as required with adequate safety measures in conformity with codes and specification of international standards. Suitable for use in tropical country like BANGLADESH. Model and sample to be approved by competent authority.

21.16.1 Suitable for maximum six storied building

21.16.1.1 30 liter / hr. (1000 ~ 1500 watt) wall mounting type.

Each	8,712.00	8,703.00	8,670.00	8,670.00
------	----------	----------	----------	----------

21.16.1.2 45 liter / hr. (1000 ~ 1500 watt) wall mounting type.

Each	9,939.00	9,931.00	9,897.00	9,897.00
------	----------	----------	----------	----------

21.16.1.3 65 liter / hr. (1500 ~ 2000 watt) wall mounting type.

Each	11,166.00	11,158.00	11,124.00	11,124.00
------	-----------	-----------	-----------	-----------

21.16.1.4 90 liter / hr. (2000 ~ 2500 watt) wall mounting type.

Each	14,234.00	14,225.00	14,192.00	14,192.00
------	-----------	-----------	-----------	-----------

21.16.1.5 110 liter / hr. (2000 ~ 2500 watt) wall mounting type.

Each	21,596.00	21,587.00	21,554.00	21,554.00
------	-----------	-----------	-----------	-----------

21.16.2 Suitable for above six storied building

21.16.2.1 30 liter / hr. (1000 ~ 1500 watt) wall mounting type.

Each	9,939.00	9,931.00	9,897.00	9,897.00
------	----------	----------	----------	----------

21.16.2.2 45 liter / hr. (1000 ~ 1500 watt) wall mounting type.

Each	11,166.00	11,158.00	11,124.00	11,124.00
------	-----------	-----------	-----------	-----------

Handwritten signatures and initials are present at the bottom of the page, including a large blue signature on the left and several smaller signatures and initials in black and blue ink across the bottom right.

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
21.16.2.3	65 liter / hr. (1500 ~ 2000 watt) wall mounting type.	Each	12,393.00	12,385.00	12,351.00	12,351.00
21.16.2.4	90 liter / hr. (2000 ~ 2500 watt) wall mounting type.	Each	15,461.00	15,452.00	15,419.00	15,419.00
21.16.2.5	110 liter / hr. (2000 ~ 2500 watt) wall mounting type.	Each	22,823.00	22,815.00	22,781.00	22,781.00
21.17	COMPONENT OF WATER HEATER					
	Providing & fixing the following component (USA / UK / ITALY / GERMANY) of the electrically operated water heater or equivalent as per sample approved by the Engineer. Brass / stainless steel immersion heating element.					
21.17.1	1000 ~ 1500 watt	Each	2,724.00	2,724.00	2,722.00	2,722.00
21.17.2	1500 ~ 2000 watt	Each	3,338.00	3,338.00	3,335.00	3,335.00
21.17.3	2000 ~ 2500 watt	Each	4,565.00	4,565.00	4,562.00	4,562.00
21.18	Adjustable type thermostat control (30° to 80°C) for electrically operated water heater.	Set	2,111.00	2,111.00	2,108.00	2,108.00
21.19	Temperature & pressure relief valve 125 psi, 99°C for electrically operated gas fired water heater.	Set	5,792.00	5,792.00	5,789.00	5,789.00
21.20	Pilot lamp	Set	2,565.00	2,565.00	2,563.00	2,563.00
21.21	Thermocouple	Set	6,405.00	6,405.00	6,403.00	6,403.00
21.22	ENERGY METER					
21.22.1	Providing & fixing 230V, 50Hz, single phase, 10 – 40 Amps electric energy meter (KWH meter) steel body with glass cover on prepared board in conformity with BDS IEC standard accepted/approved by engineer in charge.	Each	1,681.00	1,681.00	1,679.00	1,679.00

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
21.22.2	Providing & fixing 230 V, 50 Hz, single phase 10-40 Ampere electronics digital energy meter (KWH meter) steel body with glass cover on prepared board inconformity with BDS IEC standard.	Each	2,172.00	2,172.00	2,169.00	2,169.00
21.22.3	Providing & fixing 415V + 10%, 50Hz three phase electronics digital energy meter (KWH meter) steel body with glass cover on prepared board inconformity with BDS IEC standard.					
21.22.3.1	10-100 Amps (Single Tariff)	Each	6,589.00	6,589.00	6,587.00	6,587.00
21.22.3.2	10-100 Amps (Double Tariff)	Each	8,430.00	8,430.00	8,427.00	8,427.00

21.23 UPS (Off LINE)

Supply of following uninterruptible power supply (UPS) complete with central processing unit suitable for input supply 160 - 275 volt AC single phase, 50 Hz for output voltage 220 volt \pm 5%, 50 Hz single phase having protection for lightning & surge, blackout, over & under voltage, overload, battery low and over-charge etc. complete as required as per sample approved by the Engineer.

21.23.1 Back-up time : 15 minutes at full-load

21.23.1.1	600 / 650 VA	Each	5,583.00	5,582.00	5,578.00	5,578.00
21.23.1.2	1000 VA	Each	9,264.00	9,263.00	9,259.00	9,259.00
21.23.1.3	1500 VA	Each	15,461.00	15,458.00	15,450.00	15,450.00
21.23.1.4	2000 VA	Each	20,369.00	20,367.00	20,358.00	20,358.00

21.23.2 Back-up time : 30 minutes at full load.

Handwritten signatures and initials are present at the bottom of the page, including names like 'Rah', 'tu', 'g', 'Rah', 'g', 'd', 'A', and others.

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
21.23.2.1	600 / 650 VA	Each	6,847.00	6,846.00	6,838.00	6,838.00
21.23.2.2	1000 VA	Each	10,553.00	10,550.00	10,542.00	10,542.00
21.23.2.3	1500 VA	Each	18,528.00	18,526.00	18,517.00	18,517.00
21.23.2.4	2000 VA	Each	27,731.00	27,729.00	27,720.00	27,720.00
21.23.3	Back-up time : 60 minutes at full load.					
21.23.3.1	600 / 650 VA	Each	8,074.00	8,073.00	8,065.00	8,065.00
21.23.3.2	1000 VA	Each	13,007.00	13,004.00	12,996.00	12,996.00
21.23.3.3	1500 VA	Each	24,664.00	24,661.00	24,653.00	24,653.00
21.23.3.4	2000 VA	Each	39,388.00	39,386.00	39,377.00	39,377.00
21.23.4	Back-up time : 120 minutes at full load.					
21.23.4.1	600 / 650 VA	Each	37,176.00	37,175.00	37,171.00	37,171.00
21.23.4.2	1000 VA	Each	47,682.00	47,679.00	47,671.00	47,671.00
21.23.4.3	1500 VA	Each	96,575.00	96,572.00	96,564.00	96,564.00
21.23.4.4	2000 VA	Each	111,390.00	111,388.00	111,379.00	111,379.00

21.24 UPS (ON LINE) SINGLE PHASE TO SINGLE PHASE

Supply of following uninterruptible power supply (UPS) complete with central processing unit suitable for input supply 160 - 275 volt AC single phase 50 Hz for output voltage 220 volt \pm 1%, 50 Hz single phase having protection for lightning & surge, blackout, over & under voltage, overload, battery low and over-charge etc. complete as required as per sample approved by the Engineer.

21.24.1 Back-up time : 15 minutes at full-load

Handwritten signatures and initials in blue ink, including a large signature and several smaller ones, located below the text of item 21.24.1.

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
21.24.1.1	1 KVA	Each	29,572.00	29,569.00	29,561.00	29,561.00
21.24.1.2	2 KVA	Each	67,610.00	67,608.00	67,599.00	67,599.00
21.24.1.3	3 KVA	Each	73,868.00	73,863.00	73,847.00	73,847.00
21.24.1.4	6 KVA	Each	166,020.00	166,014.00	165,988.00	165,988.00
21.24.1.5	10 KVA	Each	215,102.00	215,095.00	215,070.00	215,070.00
21.24.2	Back-up time : 30 minutes at full load					
21.24.2.1	1 KVA	Each	46,751.00	46,748.00	46,740.00	46,740.00
21.24.2.2	2 KVA	Each	98,287.00	98,284.00	98,276.00	98,276.00
21.24.2.3	3 KVA	Each	110,680.00	110,675.00	110,659.00	110,659.00
21.24.2.4	6 KVA	Each	239,643.00	239,636.00	239,611.00	239,611.00
21.24.2.5	10 KVA	Each	288,725.00	288,718.00	288,693.00	288,693.00
21.24.3	Back-up time : 60 minutes at full load					
21.24.3.1	1 KVA	Each	71,292.00	71,289.00	71,280.00	71,280.00
21.24.3.2	2 KVA	Each	135,098.00	135,096.00	135,087.00	135,087.00
21.24.3.3	3 KVA	Each	178,167.00	178,163.00	178,147.00	178,147.00
21.24.3.4	6 KVA	Each	325,536.00	325,530.00	325,504.00	325,504.00
21.24.3.5	10 KVA	Each	448,241.00	448,235.00	448,209.00	448,209.00
21.24.4	Back-up time : 120 minutes at full load					

Handwritten signatures and initials are present at the bottom of the page, including a large signature on the left and several smaller ones in blue and black ink on the right.

Item No.	Description of Items	Unit	Unit Rate in Dhaka & Mymensingh Zone (Tk)	Unit Rate in Chattogram & Sylhet Zone (Tk)	Unit Rate in Khulna, Barishal & Gopalganj (Tk)	Unit Rate in Rajshahi & Rangpur (Tk)
21.24.4.1	1 KVA					
21.24.4.2	2 KVA	Each	92,151.00	92,149.00	92,140.00	92,140.00
21.24.4.3	3 KVA	Each	178,045.00	178,042.00	178,034.00	178,034.00
21.24.4.4	6 KVA	Each	221,114.00	221,109.00	221,093.00	221,093.00
21.24.4.5	10 KVA	Each	415,659.00	415,653.00	415,627.00	415,627.00
		Each	583,216.00	583,210.00	583,184.00	583,184.00

Subhead-21
Annexure-21

RECOMMENDED FAN SIZES IN ROOMS

Room Area (metre ²)	Fan Sweep
Up To 6	915 mm
Over 6 to 9	1220 mm
Over 9 to 12	1442 mm

Note : -

* Fan Spacing : 3.0 to 3.5 m (both direction).

* Fan Height : 2.5 m from the floor.

[Handwritten signatures and scribbles in black and blue ink, including the word 'Same' and various illegible marks.]

APPENDIX – A

The following things are to be considered during electro-mechanical works:

1. The minimum height for substation and Generator room is 12 feet (3-3.6 m). Each room should have 7ft width door. There should be a trench having width of 1.5ft and depth of 3.0ft around three or four sides of the room. Louvre type window and door is recommended in substation and Generator room. Adequate space (minimum 8 ft road) is required for easy and free movement of equipment in the room.
2. Adequate suitable place should be kept in the building for the solar panel system.
3. The ground station for the communication of fire-fighting should always be on the ground floor, which will simultaneously act as CCTV control, server station (if applicable), PABX, PA system control room. The staff of the Electro-Mechanical Maintenance Section should be provided with one or more rooms for seating.
4. For centrifugal pump motor, water reservoir should be adjacent to the pump room/ place, for positive pressure, the location of the room may be next to the reservoir. Adequate open space should be reserved for submersible Pump motors for boring or maintenance. Fire pumps should always be under positive pressure. If positive pressure is not possible then a turbine pump can be used.
5. The fire hydrant steel cabinet water pipe should be placed in the stairs or lift lobby.
6. Ceiling height has to be determined carefully for HVAC installation. For the central air conditioning system, the distance between the floor and the bottom of the beam is a minimum of 11ft. For hospitals, 10' X12' room/space should be kept for placing AHU on that floor. For VRF, arrangements should be made on the roof or split type on the outer wall near the room.
7. When installing other types of air conditioners, easy heat dissipation of outdoor units should be ensured.
8. One or more ducts for the medical gas pipeline should be ensured. Minimum 30' X30' room for the installation of medical gas and air plants should be provided in or near the building.
9. Lift: At least one stretcher/bed lift should be provided for ten storied or higher height buildings. A fireman lift (separately with shear wall and fire-rated core) should be arranged. There is no way the fire elevator can get to the basement. Adequate space for pit and machine room should be kept. The door should be provided according to the lift size.

Handwritten notes and signatures in blue and black ink, including initials like 'tu', 'S', 'B', 'AA', and various scribbles.

APPENDIX - B

TABLE : LOAD DENSITY

Minimum Load Densities		
Type of occupancy	Unit Load (Watt/sqm)	
	Non A.C.	A.C.
Residence/Dwelling: single family	20	75
Residence/Dwelling: Multi- family (other than Hotels)	20	75
Hospitals	32	80
Hotel including apartment house (Excluding any provisions for electric Cooking)	24	75
Office and commercial multi-storied buildings	28	75
Industrial Bldgs. (Excluding the loads for machines)	16	-
Departmental Stores	28	75
Banks	20	75
Restaurants (excluding any provisions for Electric Cooking)	16	75
Restaurants (Excluding Electric Cooking)	20	95
Barber Shops & Beauty Parlors	16	75
Schools and Colleges	12	70
Parking area in Commercial Bldg.	4	-
Warehouses, large Storage areas	2	-

APPENDIX - F

Changeover switch of a generator:

A standby generator, if needed, is to be connected at the supply input point after the energy meter and after the main incoming switch or the main incoming circuit breaker, but through a changeover switch of appropriate rating. The rating of such a switch shall be at least 1.25 times the rating of the main incoming circuit breaker. The changeover switch shall be of such a type so that when moved to the main position, there is no chance that the generator will be connected and vice versa.

APPENDIX - G

Minimum Cross-sectional Area of Copper ECCs in Relation to the Area of Associated Phase Conductors

Cross-sectional Area of Phase Conductor(s) (mm ²)	Minimum Cross-sectional Area of the Corresponding Earth Conductor (mm ²)
Less than 16	Same as the cross-sectional area of phase conductor
16 or greater but less than 35	16 mm ²
35 or greater	Half the cross-sectional area of phase conductor

[Handwritten notes and signatures in blue ink, including various scribbles and illegible text.]

APPENDIX - H**PWD CIVIL LABOUR RATES**

LABOUR & MAN-POWER:	Unit	Dhaka & Mymensingh Zone in Tk.	Chattogram & Sylhet Zone in Tk.	Khulna , Barishal & Gopalganj Zone in Tk.	Rajshahi & Rangpur Zone in Tk.
Field Engineer (minimum BSc in Eng. with 3yrs exp OR Diploma in Eng. with 8yrs exp)	per day	1,900.00	1,900.00	1,900.00	1,900.00
Head mason / Mosaic head mistry	per day	800.00	800.00	750.00	750.00
Foreman/Supervisor	per day	850.00	850.00	800.00	800.00
Polish mistry	per day	700.00	700.00	650.00	650.00
Carpenter / Painter/ Welder / Machine operator	per day	700.00	700.00	650.00	650.00
Plumber	per day	700.00	700.00	650.00	650.00
Mason / Mosaic mistry	per day	700.00	700.00	650.00	650.00
Semi skilled technician	per day	800.00	800.00	750.00	750.00
Rod binder	per day	700.00	700.00	650.00	650.00
Helper to Rod binder/Carpenter/ Plumber/Painter/Polish Mistry	per day	550.00	540.00	500.00	500.00
Ordinary labour	per day	550.00	540.00	500.00	500.00

PWD ELECTRICAL LABOUR RATES

LABOUR & MAN-POWER:		Dhaka & Mymensingh Zone in Tk.	Chattogram & Sylhet Zone in Tk.	Khulna , Barishal & Gopalganj Zone in Tk.	Rajshahi & Rangpur Zone in Tk.
Skilled technician	per day	1,200.00	1,200.00	1,200.00	1,200.00
Electrician	per day	700.00	700.00	650.00	650.00
Ordinary Labour	per day	550.00	540.00	500.00	500.00
Mason	per day	700.00	700.00	650.00	650.00
Asstt. Electrician	per day	575.00	560.00	525.00	525.00
Skilled labour	per day	600.00	580.00	550.00	550.00
Helper to Eletrician	per day	550.00	540.00	500.00	500.00